



**Underwriters  
Laboratories Inc.®**

**Northbrook Division**  
333 Pfingsten Road  
Northbrook, IL 60062-2096 USA  
www.ul.com  
tel: 1 847 272 8800

October 1, 2003

Containment Solutions, Inc.  
Mr. Bill Felts  
5150 Jefferson Chemical Rd.  
Conroe, TX 77301-6834

Our Reference: MH7991

Dear Mr. Felts:

This is to confirm that Containment Solutions, Inc.'s reinforced plastic underground storage tanks have been evaluated by Underwriters Laboratories Inc. and were found to comply with UL 1316, Standard for Glass Fiber Reinforced Plastic Underground Storage Tanks for Petroleum Products, Alcohols and Alcohol-Gasoline Mixtures.

Since its inception on 1/1/95, Containment Solutions, Inc. has been authorized by UL to apply the UL Listing Mark to those single wall and double wall underground storage tanks and compartment tanks for the storage of petroleum products, alcohols, and alcohol-gasoline mixtures, as described in the UL Follow-Up Service Inspection Procedure, MH7991. Triple wall tanks were approved and added in 1998.

This listing includes, but is not limited to, gasoline, gasoline-ethanol blends at any level of ethanol, gasoline-methanol blends at any level of methanol, 100% ethanol, and 100% methanol. See UL 1316 for other approved fuels.

If you have any questions, please contact us.

Very Truly Yours,

TIM CREWS (Ext. 42516)  
Senior Project Engineer  
Hazardous Locations, Gas & Oil

Reviewed by:

WAYNE DOVERSBERGER (Ext. 42072)  
Engineering Group Leader  
Hazardous Locations, Gas & Oil

